



**PERFORMANCE TEST REPORT**  
102687902COL-001

1717 Arlingate Lane  
Columbus, OH 43228  
Telephone: 614-279-8090  
Facsimile: 614-279-4642  
www.intertek.com

<b>Client</b>		<b>MSW Plastics Inc.</b> PO Box 29 140 Minto Road Palmerston, Ontario Canada		
<b>Project No.</b>		<b>G102687902</b>		
Sample	Product	Liner Panel		
	Model	Trusscore Liner Panel		
	Identification No.	COL1608080833-001		
	Date Received	August 01, 2016		
	Condition	New/Good		
	Production or Prototype	Production		
Procedural	Engineer	Nicholas Unger		
	Reviewer	Lee Moomaw		
	Dates Tested	August 2, 2016 – August 30, 2016		
	Report Date	August 31, 2016		
Standard	<b>ASTM G21 – 2015 Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi</b>			
Organism Species:	<i>Aspergillus brasiliensis</i> (historically known as <i>Aspergillus niger</i> )	ATCC No.:	9642	
	<i>Penicillium funiculosum</i> (historically known as <i>Penicillium pinophilum</i> )		11797	
	<i>Chaetomium globosum</i>		6205	
	<i>Trichoderma virens</i> (historically known as <i>Gliocadium virens</i> )		9645	
	<i>Aureobasidium pullulans</i>		15233	
Incubation Period:	8/2/2016 at 10:00 to 8/30/2016 at 10:00			
Test Results:	Trusscore Liner Panel	1	<b>Growth Rating:</b>	0
		2		0
		3		0

**Result Interpretation:**

Samples received an average growth rating of **0** meaning there was **No Growth (0%)** on the test specimens at the completion of the fungal resistance evaluation. This was confirmed with use of a microscope (power 40X and 100X). The effects of growth on physical, optical, or electrical properties were not evaluated.

Test Performed by:

Nicholas Unger  
Project Engineer  
Columbus Office

Report Approved by:


Lee Moomaw  
Engineer  
Columbus Office

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program

**Photos:**



**Figure 1.** Representative Sample 1 Post Incubation



**Figure 2.** Representative Sample 2 Post Incubation



**Figure 1.** Representative Sample 3 Post Incubation



**Figure 4.** 100x View of Positive Control Sample